



IMPORTANT:
ALL INSTALLATION WIRING TO COMPLY WITH CURRENT EDITION OF IEE REGULATIONS. CONNECT MAINS FEED TO UNIT VIA FUSED SPUR BOX OR SIMILAR (3A RATED). OTHER CONNECTION WIRING TO UNIT MUST BE VIA SUPPLIED CUSTOMER CONNECTION BOX (WHERE SHOWN). NON COMPLIANCE WITH ABOVE MAY RESULT IN VOIDING OF WARRANTY.

SPC HOUSE, Evington Valley Rd,
Leicester. LE5 5LU
TEL:-0116-2490044.FAX-2490033
E-MAIL :- SPC@SPC-HVAC.CO.UK

					TITLE CIRRUS UNIT HEATER EC ELECTRIC 9kW 3 PHASE + BMS1 OPTIONS GUIDE	
1		11/05/23	SB	-	DRG No.	WUHO4
ISS	ECN	DATE	DRN	CHKD		ISSUE 1